

HIGH SCHOOL LEAD IN WATER TESTING

Adirondack Environmental Services			
LEAD WATER TESTING 2020			
Acceptable Limit - <15 ppm			
SAMPLE ID#	SAMPLE LOCATION	DATE SAMPLED	RESULTS
HS 1	ROOM 100 SHOP SINK	9/29/2020	2.1
HS 2	ROOM 101 GREENHOUSE 2 BAY SINK	9/29/2020	1.0
HS 3	ROOM 101 HAND WASH SINK GREENHOUSE	9/29/2020	2.5
HS 4	ROOM 102 SINK	9/29/2020	ND
HS 5	ICE MAKER	9/29/2020	5.7
HS 6	KITCHEN DISH WASH ROOM SINK	9/29/2020	ND
HS 7	KITCHEN HAND WASH SINK	9/29/2020	1.7
HS 8	KITCHEN STEAM KETTLE	9/29/2020	2.0
HS 9	KITCHEN 3 BAY SINK	9/29/2020	ND
HS 10	HALLWAY DRINKING FOUNTAIN NEAR CAFE	9/29/2020	ND
HS 11	ROOM 106 DRINKING FOUNTAIN	9/29/2020	ND
HS 12	MAIN HALLWAY BOYS BATHROOM SINK 1 LEFT	9/29/2020	ND
HS 13	MAIN HALLWAY BOYS BATHROOM SINK 2	9/29/2020	ND
HS 14	MAIN HALLWAY BOYS BATHROOM SINK 3 RIGHT	9/29/2020	ND
HS 15	NOT USED		
HS 16	HALLWAY DRINKING FOUNTAIN NEAR MAIN OFFICE	9/29/2020	ND
HS 17	NURSES OFFICE SINK 1 ATTENDANCE ROOM	9/29/2020	ND
HS 18	NURSES OFFICE SINK 2	9/29/2020	ND
HS 19	NURSES OFFICE BATHROOM SINK	9/29/2020	ND
HS 20	FACULTY ROOM SINK	9/29/2020	3.1
HS 21	FACULTY BATHROOM MENS SINK LEFT	9/29/2020	1.7
HS 22	FACULTY BATHROOM MENS SINK RIGHT	9/29/2020	ND
HS 23	FACULTY BATHROOM WOMENS SINK LEFT	9/29/2020	1.2
HS 24	FACULTY BATHROOM WOMENS SINK RIGHT	9/29/2020	ND
HS 25	ROOM 121 SINK	9/29/2020	76.2
HS 26	HALLWAY DRINKING FOUNTAIN NEAR ROOM 121	9/29/2020	ND
HS 27	GYM DRINKING FOUNTAIN BOYS SIDE	9/29/2020	ND
HS 28	BOYS LOCKER ROOM SINK 1 LEFT	9/29/2020	ND
HS 29	BOYS LOCKER ROOM SINK 2	9/29/2020	3.7
HS 30	BOYS LOCKER ROOM SINK 3	9/29/2020	3.3
HS 31	BOYS LOCKER ROOM SINK 4 RIGHT	9/29/2020	ND
HS 32	GYM DRINKING FOUNTAIN GIRLS SIDE	9/29/2020	ND
HS 33	GIRLS LOCKER ROOM SINK 1 LEFT	9/29/2020	ND
HS 34	GIRLS LOCKER ROOM SINK 2	9/29/2020	ND
HS 35	GIRLS LOCKER ROOM SINK 3	9/29/2020	ND
HS 36	GIRLS LOCKER ROOM SINK 4 RIGHT	9/29/2020	ND
HS 37	GIRLS OUTSIDE BATHROOM SINK	9/29/2020	ND
HS 38	BOYS OUTSIDE BATHROOM SINK	9/29/2020	ND
HS 39	JR HIGH BOYS BATHROOM SINK 1 LEFT	9/29/2020	ND
HS 40	JR HIGH BOYS BATHROOM SINK 2	9/29/2020	ND
HS 41	JR HIGH BOYS BATHROOM SINK 3	9/29/2020	ND
HS 42	MAIN HALLWAY GIRLS BATHROOM SINK 1 LEFT	9/29/2020	ND
HS 43	HALLWAY DRINKING FOUNTAIN NEAR ROOM 311	9/29/2020	ND
HS 44	MEDIA CENTER OFFICE SINK	9/29/2020	ND
HS 45	ROOM 204 SINK 1 LEFT SIDE LEFT SINK	9/29/2020	ND
HS 46	ROOM 204 SINK 2 LEFT SIDE RIGHT SINK	9/29/2020	ND
HS 47	ROOM 204 SINK 3 RIGHT SIDE LEFT SINK	9/29/2020	ND
HS 48	ROOM 204 SINK 4 RIGHT SIDE RIGHT SINK	9/29/2020	3.7
HS 49	2ND FLOOR BOYS BATHROOM SINK 1 LEFT	9/29/2020	ND
HS 50	2ND FLOOR BOYS BATHROOM SINK 2	9/29/2020	ND
HS 51	2ND FLOOR BOYS BATHROOM SINK 3	9/29/2020	ND
HS 52	MAIN HALLWAY GIRLS BATHROOM SINK 2	9/29/2020	ND

HIGH SCHOOL LEAD IN WATER TESTING

HS 53	HALLWAY DRINKING FOUNTAIN NEAR ROOM 207	9/29/2020	ND	
HS 54	2ND FLOOR GIRLS BATHROOM SINK 1 LEFT	9/29/2020	ND	
HS 55	2ND FLOOR GIRLS BATHROOM SINK 2	9/29/2020	ND	
HS 56	2ND FLOOR GIRLS BATHROOM SINK 3	9/29/2020	ND	
HS 57	MAIN HALLWAY GIRLS BATHROOM SINK 3 RIGHT	9/29/2020	ND	
HS 58	HALLWAY DRINKING FOUNTAIN NEAR ROOM 217 LEFT	9/29/2020	ND	
HS 59	HALLWAY DRINKING FOUNTAIN NEAR ROOM 217 RIGHT	9/29/2020	ND	
HS 60	CONCESSION STAND SINK	9/29/2020		3.0
HS 61	WATER SHED BY TRACK HOSE SPIGOT	9/29/2020	ND	
HS 62	WATER SHED BY TRACK DRINKING FOUNTAIN 1 LEFT	9/29/2020		1.6
HS 63	WATER SHED BY TRACK DRINKING FOUNTAIN 2 RIGHT	9/29/2020	ND	
HS 64	YARD HYDRANT BY PRACTICE FOOTBALL FIELD	9/29/2020		4.7
HS 65	YARD HYDRANT BY BACK SOCCER FIELD	9/29/2020	ND	
HS 66	JR HIGH GIRLS BATHROOM SINK 1 LEFT	9/29/2020	ND	
HS 67	JR HIGH GIRLS BATHROOM SINK 2	9/29/2020	ND	
HS 68	JR HIGH GIRLS BATHROOM SINK 3 RIGHT	9/29/2020	ND	
TOTAL 67 SAMPLED				
NON POTABLE WATER				
ALL 9 CUSTODIAL CLOSETS WITH WATER				
ROOM 101 EYE WASH IN GREENHOUSE				
ROOM 106 EYE WASH				
KITCHEN PRE-WASH SPRAYER				
KITCHEN BATHROOM SINK				
ROOM 106 WOOD SHOP (1) 3 BAY SINK (1) SINGLE SINK				
ROOM 301 ART ROOM (2) 3 BAY SINKS (1) SINGLE SINK				
ROOM 302 ART ROOM (2) 3 BAY SINKS (1) SINGLE SINK				
ROOM 310 SCIENCE ROOM (3) SINKS				
ROOM 312 SCIENCE ROOM (3) SINKS				
ROOM 207 SCIENCE ROOM (3) SINKS (1) EMERGENCY SHOWER (1) EYE WASH				
ROOM 208 SCIENCE ROOM (1) SINGLE SINK (6) DOUBLE SINKS (1) EMERGENCY SHOWER (1) EYE WASH				
ROOM 210 SCIENCE PREP ROOM (1) SINGLE SINK				
ROOM 212 SCIENCE ROOM (1) SINGLE SINK (6) DOUBLE SINKS (1) EMERGENCY SHOWER (1) EYE WASH				
ROOM 214 SCIENCE PREP ROOM (1) SINGLE SINK				
ROOM 216 SCIENCE ROOM (1) SINGLE SINK (6) DOUBLE SINKS (1) EMERGENCY SHOWER (1) EYE WASH				
COACHES OFFICE BOYS SIDE (1) SINK (1) SHOWER				
COACHES/OFFICIALS LOCKER ROOM BOYS SIDE (1) SINK (1) SHOWER				
BOYS LOCKER ROOM (8) SHOWERS				
COACHES OFFICE GIRLS SIDE (1) SINK (1) SHOWER				
COACHES/OFFICIALS LOCKER ROOM GIRLS SIDE (1) SINK (1) SHOWER				
GIRLS LOCKER ROOM (8) SHOWERS				
SINK IN BOILER ROOM				